



PUBLIC HEALTH ENGINEERING DEPARTMENT DRINKING WATER TESTING LABORATORY, PALWAL
9MLD STP, JODHPUR ROAD, PALWAL, HARYANA - 121102
E-mail:-chemist.palwal@phedharyana.gov.in, chemist.palwal@gmail.com

PHED
Haryana

TC-4091

TEST REPORT

Issued to : → J.D. Public School	Location: → Lalpur, Quadim
Test Report No. : → PWL/01770/8/2024	Collected by: → Mahender Singh
Reference No. : → 4306 /dt. 09/08/2024	Sample collected Date & Time : → 12/08/2024 at 10:30
Sample Type : → R.O.	Sample received Date & Time: → 12/08/2024 at 12:00
Test Type : → Chemical Test	Date of Analysis Started : → 12/08/2024
Classification of Sample : → Private	Date of Analysis Completed : → 12/08/2024
Sample Description : → Water Sample Received in food grade plastic bottle at room temperature	Sample Quantity : → 1000 ml
Lab Job Order No.: → V-353	Issue Date of Report:- 13/08/2024
	Addition/Deviation/ Exclusions from the method :- NA

Test Result

Sl. No.	Tested Parameter	Results	Unit	Method	As per IS 10500:2012 RA 2018	
					Acceptable	Permissible Limit
1.	Turbidity	<1	NTU	APHA 24th Edition-2130-B	1 NTU	5 NTU
2.	Taste	Agreeable		IS 3025 (Part-8) 1984:RA 2023	Agreeable	Agreeable
3.	Odour	Agreeable		IS 3025 (Part-5) 1983:2018	Agreeable	Agreeable
4.	Colour	<5	CU	APHA 24th Edition-2120 - B	5 CU	15 CU
5.	Total Dissolve Solids (180°C ± 2°C)	210	mg/l	APHA 24th Edition-2540 C	500 mg/l	2000 mg/l
6.	Total Hardness as CaCO ₃	50	mg/l	APHA 24th Edition-2340 C	200 mg/l	600 mg/l
7.	Calcium as (Ca)	9.61	mg/l	APHA 24th Edition-3500-Ca B	75 mg/l	200 mg/l
8.	Magnesium (Mg)	6.31	mg/l	APHA 24th Edition-3500-Mg B	30 mg/l	100 mg/l
9.	Total Alkalinity	30	mg/l	APHA 24th Edition-2320 B	200 mg/l	600 mg/l
10.	Chlorides as Cl	45.98	mg/l	APHA 24th Edition-4500-Cl B	250 mg/l	1000 mg/l
11.	Sulphate as (SO ₄)	20	mg/l	APHA 24th Edition-4500-SO ₄ E	200 mg/l	400 mg/l
12.	Fluoride as (F)	0.26	mg/l	APHA 24th Edition-4500-F D	1.0 mg/l	1.5 mg/l
13.	Iron as (Fe)	0.01	mg/l	APHA 24th Edition-3500-Fe B	1.0 mg/l	No Relaxation
14.	Nitrate as (NO ₃)	3.4	mg/l	APHA 24th Edition-4500-NO ₃ D	45 mg/l	No Relaxation
15.	pH (@25°C)	6.97	---	APHA 24th Edition-4500-H B	6.5-8.5	No Relaxation

Remarks:-

Specific contractual notes:-

- The results given above are related to the sample as received and tested in PHED Lab PALWAL.
- The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab PALWAL.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample lies with sender/collector of water sample

CHEMIST (REENA)
PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY
PALWAL

END OF REPORT

PHEDPWLT-101